



Rhode Island Department of Business Regulation

Contractors' Registration and Licensing Board

560 Jefferson Blvd. Ste. 200, Warwick, Rhode Island 02886

Telephone: (401) 921-1590 Fax: (401) 889-5535

VIA- USPS

March 17, 2022

Aliav Moyal

Registration/License Number:
Claim Associated with Violation: C-C-10646

RE: FINAL ORDER -Disciplinary Action- Violation # V-6257

On or about January 25, 2022 , you were provided with notice that the Rhode Island Contractors' Registration and Licensing Board determined that you were in violation of the following section(s) of Rhode Island General Law and intended to assess civil penalties as proposed

Violation

5-65-3(o) - Failure to have written contract when work performed is in excess of \$1,000.00

Violation Penalty

1,000

Description

Respondent entered in an agreement to perform work at (261 Glen Hills Drive Cranston) on or about (7/2/21). The agreed upon value of the work was (\$2675.00). Upon request, Respondent stated that there was no written contract and Upon request, no written contract was produced.

Violation

5-65-10(a)(10) - Performed work, or arranged to perform work, without a valid registration.

Violation Penalty

1,000

Description

On July 2, 2021, respondent entered into a Contract to Install a New Garage Door System at 261 Glen Hills Drive Cranston. This work is of the type which requires registration with the CRLB. When asked for proof or registration, the respondent stated that he was not registered with the CRLB and a check of the CRLB Registration database showed that the respondent was not registered with the CRLB.

Violation

5-65-10(a)(12) - Contractor performed improper work

Violation Penalty

1,000

Description

On or about (7/2/2021), respondent performed the Installation of a New Garage Door. Upon inspection, this work was deemed improper because of the following:

- No Reinforcing Bar to support the Top Panel due to Glass Windows which weakens the Panel Strength
- Re using the Original Tracks, which show signs of wear, the rollers on the New Door are barely being held in place to support the Door during the Opening and Closing operations
- The Door Opener itself was not calibrated to the new Doors weight, which caused the system to operate poorly, not a smooth opening and closing of the door system when under Power

Violation

5-65-18 - Failure to provide mechanic's lien notice

Violation Penalty

1,000

Description

Contracts for work require notice that the contractor provide the consumer with a notice that the contractor may file a lien in accordance with the Mechanic' Lien Law, as found in R.I. Gen. Law 34-28. As there was no written contract, the required notice was not provided to the consumer.

Fine amount: \$4,000

Because you did not request a hearing within the time allowed, the Proposed Order has converted to a Final Order. The fines, as listed above, are now due and payable. If payment is not received within twenty (20) days, your case may be referred to the Office of the Attorney General for criminal prosecution pursuant to RIGL § 5-65-19.

Alternatively, you may appeal this Final Order in writing, within twenty (20) days of the date of this mailing to the Contractors' Registration and Licensing Board. For additional information, please see our website at www.crb.ri.gov, or contact us by telephone at (401) 921-1590.

Sincerely,